

VILLAGE OF WILMETTE
STORMWATER INCENTIVE PROGRAM
MINIMUM REQUIREMENTS FOR PLAN SUBMITTAL

Submittal of an application for the Stormwater Incentive Program shall be accompanied by a plan detailing the proposed eligible improvements. The plan shall meet the below minimum specifications and include the minimum level of detail:

1. The plan shall be submitted on or accompanied by a clean plat of survey.
2. The plan shall be submitted on paper measuring 11 inches by 17 inches and drawn at a scale of 1:20.
3. A north arrow, scale, and legend, as may be applicable.
4. The property boundaries.
5. Location of existing buildings, structures, and hardscape features (i.e. decks, patios, sidewalks, etc.).
6. Location of downspouts and sump pump discharges as may be applicable.
7. Location of any existing private storm sewer, yard drains, drywells, etc. as may be applicable.
8. Location of any proposed private storm sewer systems as may be applicable. Private storm sewers must meet the following requirements:
 - Storm sewers must be a minimum of 6 inches in diameter, and be PVC SDR 26 or equivalent.
 - Storm sewers must be a minimum of 3 feet below grade.
 - Storm sewers must have a minimum 1% slope throughout.
 - Inlets must be provided for any proposed drywells.
9. Location and description of any proposed stormwater best management practices as may be applicable.
10. For reference, examples of stormwater management installations can be found in the Wilmette Department of Engineering and Public Works Standards Handbook. The standards indicate the minimum specifications required for construction of installations such as:
 - Sump Pump Discharge Connections
 - Buried Downspout Discharges
 - Yard Inlet/Outlet Structures
 - Perforated Drain Lines
 - Drywells
 - Permeable Pavement
 - Rain Gardens
 - Rain Barrels